

UNOFFICIAL

**TITLE 785. OKLAHOMA WATER RESOURCES BOARD
CHAPTER 35. WELL DRILLER AND PUMP INSTALLER LICENSING**

Introduction:

This document contains permanent amendments to Chapter 35 adopted by the Oklahoma Water Resources Board that became effective July 1, 2006. Also, this document was prepared by Oklahoma Water Resources Board staff as a convenience to the reader, and is not a copy of the official Title 785 of the Oklahoma Administrative Code. The rules in the official Oklahoma Administrative Code control if there are any discrepancies between the Code and this document.

Subchapter Section	Section
1. General Provisions	785:35-1-1
3. Licensing and Certifications.....	785:35-3-1
5. General Requirements to Maintain Licenses and Operator Certifications.....	785:35-5-1
7. Minimum Standards for Construction of Wells	785:35-7-1
9. Minimum Standards for Pump Installation.....	785:35-9-1
11. Plugging and Capping Requirements.....	785:35-11-1

[Authority: 82 O.S., Sections 1020.16 and 1085.2]

**SUBCHAPTER 1.
GENERAL PROVISIONS**

Section	Purpose
785:35-1-1.	Purpose
785:35-1-2.	Definitions
785:35-1-3.	General statutory authority
785:35-1-4.	Violations and penalties
785:35-1-5.	Indemnity Fund
785:35-1-6.	Well Drillers and Pump Installers Advisory Council

785:35-1-1. Purpose

(a) Rules in this chapter set forth the requirements to obtain a license to drill certain kinds of wells and to install pumps in such wells. These rules also provide guidance and procedures followed for license renewal, revocations, and suspensions, requirements licensees must meet to retain their licenses, specify the purposes for the indemnity fund created to replace the bond requirement, and provide for the establishment of an advisory committee of well drillers and pump installers to make recommendations to the Board.

(b) The rules in this Chapter also provide minimum requirements to be followed by any person when drilling and plugging certain kinds of wells and installing pumps in such wells. Other agencies may have standards for drilling and plugging which exceed the minimum standards in this Section. These requirements are primarily

promulgated to protect the quantity and quality of the fresh groundwater in the state from contamination and waste, and to provide public protection by enforcing proper construction, plugging and installing activities.

[Source: Amended at 10 Ok Reg 3299, eff 6-25-93; Amended at 11 Ok Reg 2947, eff 6-13-94]

785:35-1-2. Definitions

The following words and terms, when used in this Chapter, shall have the following meaning, unless the context clearly indicates otherwise:

"Abandoned well" means a well that has been permanently taken out of use, or is in such a state of disrepair that using it is impracticable or threatens to contaminate the groundwaters of the State.

"APA" means and refers to the Oklahoma Administrative Procedures Act set forth in 75 O.S. 1981, §§250 et seq., as amended.

"Application" means a formal request to the Board and the first step required by law to acquire the right to perform or engage in activities regulated by the Board.

"Board" means the Oklahoma Water Resources Board authorized by law to make final adjudications, execute contracts, adopt rules and carry out other powers and duties set forth by law or, for duties authorized by law to be delegated to

the Executive Director, the Executive Director or any employee or agent or staff member thereof as assigned by the Executive Director.

"Commercial drilling" means *drilling and installation as a business, trade, or occupation for compensation.* [82:1010.1]

"Commercial installation" means *installation as a business, trade or occupation for compensation.* [82:1020.1]

"Commercial plugging" means plugging wells or borings *as a business, trade or occupation for compensation.* [82:1020.1]

"Direct push geological boring" means a geological boring in which tools and sensors are pushed into the ground using static weight combined with percussion as the energy to remove soil or make a path for the tool to obtain geotechnical, soil, water, and/or vapor information.

"Drilling water" means water that is used in the drilling of a well which is of a quality suitable for drinking or is uncontaminated water with a residual chlorine content equal to or greater than one hundred (100) milligrams per liter.

"Firm" means an individual or any kind of legal entity, such as a sole proprietorship, partnership or corporation that holds a license to conduct any well drilling or pump installation activity.

"Fresh water observation well" means any well used to measure the depth to the water table or parameters of fresh water aquifer performance.

"Geotechnical boring" means any excavation deeper than four feet (4'), that is drilled, augured, bored, cored, washed, driven, jetted or otherwise constructed and which is used or capable of being used to obtain soil or geological formation samples or information, or for the determination of groundwater quality or remediation.

"Geothermal well" means heat pump well.

"Groundwater well" means any excavation that is drilled, cored, bored, washed, driven, dug, jetted or otherwise constructed which is used or is capable of being used for the production of groundwater.

"Heat exchange well" means the same as, and includes, the terms "geothermal well", "heat pump well", and "heat sink well".

"Heat pump well" means a boring or cased hole that uses or is capable of using the thermal

characteristics of the geologic formations or groundwater if encountered, and includes but is not limited to an open or closed loop groundwater heat pump system.

"Heat sink well" means a well utilized for heat exchange purposes, including but not limited to, a heat pump well and a geothermal well.

"License" means a certification issued by the Board to qualified persons making application therefor authorizing such persons to engage in weather modification and control operations or the business of drilling or plugging wells or borings and installing water well pumps.

"Monitoring well" means a well used to obtain a representative groundwater sample for determining groundwater chemistry or quality; for detecting, recovering, or remediation of actual or potential contamination; or for monitoring the unsaturated zone above a water table or confined aquifer, and includes site assessment observation wells and unsaturated zone monitoring wells.

"Open-loop heat pump water supply well" means a well drilled to supply water for the purpose of heat transfer.

"Operator" means the individual person engaging in the actual operation and use of the well drilling equipment and facilities and who performs and supervises the actual on-site construction, completion and handling of wells or well test holes, and conducts tests, and obtains and records well or well test hole data.

"Piezometer" means cased holes that monitor or are capable of monitoring water pressures or soil moisture tensions, primarily located at dam sites or other man-made water retention structures.

"Pump" means mechanical equipment or device used to remove water from wells and shall include, but is not limited to pumps, seals, tanks, fittings, pipes from wells to pressure tanks, pressure switches, shut off valves for pressure tanks, related equipment and controls.

"Pump installer" means a person who is qualified to engage in the installation, removal, alteration, or repair of water well pumps and pumping equipment used in connection with a water well and breaking of the water well seal.

"Sand point well" means a groundwater well with a borehole constructed by means of driving a small diameter pipe having perforations downward

into a loose sandy soil or by means of forcing uncontaminated groundwater through a small diameter pipe having perforations with sufficient pressure to displace loose sandy soil with the pipe.

"Site assessment observation well" means a well used to measure the depth to the water when used for evaluation, classification or determination of the groundwater flow direction at a site that is or might be contaminated.

"Sleeve" means well casing that is installed at the surface surrounding the production casing and used solely for the purpose of attaching a pitless adapter unit and is separate from surface casing and conductor pipe.

"Unsaturated zone monitoring well" means any well used for the characterization, evaluation or monitoring of the unsaturated area above the water table or zone.

"Vertical closed-loop heat pump well" means the borehole perpendicular to the natural grade of the earth surface drilled deeper than ten (10) feet into which a closed-loop pipe is placed for the purpose of heat transfer.

"Water return well" means a well constructed for the purpose of returning water that has passed through the heat pump system to the same aquifer from which the water was produced by the open-loop water supply well.

"Water well test hole" means any excavation that is drilled, cored, bored, washed, driven, dug, jetted or otherwise constructed which is used or is capable of being used to determine the location of fresh groundwater and/or the capacity of the geologic formation to yield groundwater.

"Well" means any type of excavation for the purpose of obtaining groundwater, to monitor, to remediate, or observe conditions under the surface of the earth, but does not include oil and gas wells.

"Well driller" means and refers to the individual owner-proprietor or partnership, firm or corporation engaged in the business of the commercial drilling, plugging or reconstruction and the test drilling of wells in the State of Oklahoma.

[Source: Amended at 9 Ok Reg 1679, eff 5-11-92; Amended at 10 Ok Reg 3299, eff 6-25-93; Amended at 11 Ok Reg 2947, eff 6-13-94; Amended at 12 Ok Reg 2703, eff 7-1-95; Amended at 14 Ok Reg 2782, eff 7-1-97; Amended at 20 Ok Reg _____, eff 7-11-2003;

Amended at 21 Ok Reg 2633, eff 7-1-2004; Amended at 22 Ok Reg _____, eff 7-1-2005; Amended at 23 Ok Reg _____, eff 7-17-2006]

785:35-1-3. General statutory authority

The Oklahoma Water Resources Board, under directive of 82 O.S. 1991, §§1020.16 and 1085.2, as amended, is required to adopt appropriate rules and regulations governing applications for licensing persons engaged in the commercial drilling or plugging of groundwater, monitoring and fresh water or site assessment observation wells, wells utilized for heat exchange purposes, including but not limited to heat pump wells and geothermal wells, and in the drilling of geotechnical boring, for the proper completion of groundwater, monitoring and fresh water or site assessment observation wells and wells used for heat exchange purposes and geotechnical boring drilled in the State of Oklahoma, and for the licensing of pump installers and for the proper installation of pumps. The rules and regulations contained in this Chapter are adopted for the purpose of performing the duties of licensing well drillers and pump installers as directed by law.

[Source: Amended at 10 Ok Reg 3299, eff 6-25-93; Amended at 11 Ok Reg 2947, eff 6-13-94]

785:35-1-4. Violations and penalties

(a) **Misdemeanor violations.** Any person who, after notice from the Board violates or refuses or neglects to comply with any provision of 82 O.S. 1991, §§1020.1 through 1020.22, as amended and the rules of this Chapter, or who commits waste shall be guilty of a misdemeanor, and upon conviction shall be fined not less than Twenty-Five Dollars (\$25.00) nor more than Two Hundred Fifty Dollars (\$250.00) for each offense. Any person who, after notice that he is in violation thereof continues to violate any provision of this act, and fails to comply therewith within a reasonable length of time, is guilty of a separate offense for each day the violation continues.

(b) **Administrative penalties.** *The Board may, after notice and hearing, impose administrative penalties of up to Five Hundred Dollars (\$500) and may revoke, suspend or deny renewal of the license or operator certification for each violation of the Board's rules and regulations regarding license or certification requirements or minimum construction or installation standards. Each day a*

violation continues shall constitute a separate violation. Such administrative penalties shall be deposited in the Well Drillers and Pump Installers Remedial Action Indemnity Fund except as otherwise provided in 785:35-1-5(c).
[82:1020.16(E)]

(1) Notice of violation and proposed assessment.

In addition to revoking, suspending or not renewing a license or operator certification, the Board may impose administrative penalties against drillers or operators who fail, refuse or neglect to comply with rules or orders of the Board. Such administrative penalties shall be imposed only after notice and opportunity for hearing on the proposed imposition of such penalties. The notice of the proposed assessment of administrative penalties shall inform the respondent of the provisions of the Board rules or order at issue and the proposed amount of the penalty. A letter, petition, notice of violation, consent order or final order may constitute a notice of proposed assessment for purposes of initiating administrative penalty proceedings if it meets the requirements of this section.

(2) Determining amount of penalty. In setting the administrative penalty amount, the Board may consider the following:

- (A) The nature, duration and number of previous instances of failure by respondent to comply with requirements of law, Board rules and orders;
- (B) The efforts of the driller or operator to correct deficiencies or other instances of failure to comply with the requirements of law, Board rules and orders subject of the proposed penalty;
- (C) The cost of carrying out actions required to meet the requirements of law and Board rules and orders;
- (D) Any established penalty set forth in these rules;
- (E) Other factors deemed appropriate by the Board.

(3) Procedures for penalty assessment.

- (A) The notice of proposed assessment of administrative penalties shall specify a time, date and place for a hearing.
- (B) Failure of respondent to appear at the hearing shall be deemed to constitute

an agreement with the imposition of the penalty in the amount proposed as set forth in the notice, and proposed findings, conclusions and order shall not be prepared in that instance. The Board and respondent may also agree to an informal disposition of the matter. In either situation, the matter shall be presented to the Board for consideration of entering a final order assessing the administrative penalty.

(C) The administrative penalty is due and payable immediately upon issuance of the final order, unless otherwise provided therein.

(D) If the Board believes that violations are continuing after issuance of the administrative penalty order, it may seek the issuance of additional orders to assess penalties occurring in the period after issuance of the previous assessment orders.

(4) Established penalty for failure to submit reports.

Unless otherwise specifically determined by the Board, the penalties to be assessed for the failure to submit multipurpose completion reports within sixty (60) days after completion of the activity as required by Board rules shall be as follows, provided that to avoid such an assessment the Board may from time to time provide an amnesty period of a duration and under such conditions to be set forth in a written notice to be provided to all licensees:

- (A) For the first time penalties are assessed against a licensee or operator for failure to submit such reports, \$50 for each report, provided that the licensee or operator shall submit an acceptable report with the associated penalty within thirty (30) days after receipt of the notice; and
- (B) For the second or additional times that penalties are assessed against a licensee or operator for failure to submit such reports, \$250 for each report, provided that the licensee or operator shall submit an acceptable report with the associated penalty within thirty (30) days after receipt of the notice.

[Source: Amended at 11 Ok Reg 2947, eff 6-13-94; Amended at 20 Ok Reg ____, eff 7-11-2003]

785:35-1-5. Indemnity Fund

(a) **Purpose of the Indemnity Fund.** *Monies in the Indemnity Fund shall only be expended for remedial actions necessary without notice and hearing to protect groundwater from pollution or potential pollution from wells or boreholes that do not meet the minimum standards for construction or that have been abandoned. [82:1020.16(B)(2)] Expenditures from the indemnity fund...shall not exceed Five Thousand Dollars (\$5,000.00) for each well, borehole, or pump for which action is taken. [82:1020.16(B)(4)]* Monies from the Indemnity Fund shall be expended solely for the repair or plugging of improperly constructed wells. Unless otherwise determined by the Board, a finding that a well has been improperly constructed shall be based on the rules and statutes in place at the time the well was constructed.

(b) **Reimbursement.** The establishment of the Indemnity Fund in no way relieves the driller or pump installer from liability incurred or responsibility for wells or boreholes drilled or plugged or pumps installed which are not in compliance with the Board's rules and regulations. If the Board makes an expenditure from the Indemnity Fund to remedy a deficient condition, then any driller or pump installer responsible therefor shall, within a reasonable time specified in a written notification by the Board, reimburse the Indemnity Fund for the full amount of the expenditure. If the driller or pump installer does not make such reimbursement, then the Board shall not renew the license or certification of the driller or pump installer and may pursue other available remedies. *The Board shall seek reimbursement as recommended by the Well Drillers and Pump Installers Advisory Council for any remedial action taken or required by the Board.* Any monies received as reimbursement shall be deposited in the Well Drillers and Pump Installers Remedial Action Indemnity Fund except as otherwise provided in 785:35-1-5(c). [82:1020.16(B)(5)]

(c) **Well Drillers and Pump Installers Regulation Account.** When the Well Drillers and Pump Installers Remedial Action Indemnity Fund reaches Fifty Thousand Dollars (\$50,000.00), the annual fees received from well drillers and pump installers, *monies received as reimbursement, and administrative penalties recovered under 785:35-1-*

4(b) [82:1020.16(C)] shall be deposited in a separate account in the *Water Resources Board Revolving Fund* designated as the Well Drillers and Pump Installers Regulation Account. *Monies in said account shall be used by the Board for inspections, licensing, enforcement, and education, reimbursing per diem and travel costs for members of the Well Drillers and Pump Installers Advisory Council pursuant to the State Travel Reimbursement Act, and as otherwise determined to be necessary to implement the provisions of this section [82:1020.16(C)], including but not limited to the payment for damage or destruction of property caused by activities related to inspections and enforcement by the Board.*

[Source: Amended at 10 Ok Reg 3299, eff 6-25-93; Amended at 11 Ok Reg 2947, eff 6-13-94; Amended at 14 Ok Reg 2783, eff 7-1-97; Amended at 18 Ok Reg 2247, eff 7-1-2001; Amended at 19 Ok Reg 2500, eff 7-1-2002]

785:35-1-6. Well Drillers and Pump installers

(a) **Creation of Council.** The Well Drillers and Pump Installers Advisory Council is hereby created. The Council shall consist of eight (8) members appointed by and serving at the pleasure of the Oklahoma Water Resources Board. The Board shall seek nominations from each of the Congressional districts and the remaining members shall be appointed at large. The Executive Director of the Board shall be a member ex officio. At least one member shall represent each licensed activity. Three members shall be appointed for a term of one (1) year; three members shall be appointed for a term of two (2) years; and two members shall be appointed for a term of three (3) years. Upon the expiration of said terms, their successors shall be appointed for terms of three (3) years. Council members may be removed by the Board without cause.

(b) **Qualifications for Council membership.** Each Council member shall have been licensed as a well driller or pump installer by the Board for at least five (5) years prior to appointment to the Council, and must be in good standing with the Board at the time of appointment and during the term of Council membership.

(c) **Organization of Council.** The Council shall meet at least once each twelve months and otherwise at the call of the Board or Executive

Director of the Board. The Executive Director or his or her designee shall chair the first Council meeting, at which the Council members may elect a chair for a term of one year from among their membership. In the event of a vacancy on the Council, the remaining Council members may make nominations or recommendations, subject to approval and appointment by the Board. The Executive Director or his or her designee will consult with an elected chair concerning meeting agendas.

(d) **Duties of the Council.** The Council shall have the following duties:

(1) Recommend new rules and rules amendments to the Board, provided such recommendations must be in writing and must be concurred in by a majority of the membership of the Council;

(2) Review and recommend approval or denial of use of monies in the Well Drillers and Pump Installers Remedial Action Indemnity Fund for:

(A) Remedial actions to protect groundwater from pollution or potential pollution from wells or boreholes under the jurisdiction of the Board which do not meet minimum standards for construction or that have been abandoned, and

(B) Inspections, licensing, enforcement and education by the Board; and

(3) Recommend seeking reimbursement for any remedial action taken or required by the Board.

(e) **Effect of rule.** Nothing in this section shall be construed to limit or restrict the Board's authority regarding water well and pump installer licensing or use of the Well Drillers and Pump Installers Remedial Action Indemnity Fund.

[Source: Amended at 10 Ok Reg 3299, eff 6-25-93; Amended at 19 Ok Reg 2500, eff 7-1-2002; Amended at 20 Ok Reg _____, eff 7-11-2003]

SUBCHAPTER 3. LICENSING AND CERTIFICATIONS

Section

- 785:35-3-1. Licensing procedures
 785:35-3-1.1 Activities authorized; electrician and plumbing license
 785:35-3-2. Expiration and renewal of licenses and certifications
 785:35-3-3. Revocation, suspension or non-

renewal of licenses and certifications

785:35-3-1. Licensing procedures

(a) **Who must file and types of certifications.**

(1) All persons engaged in the following categories of activities in this state shall make application for and obtain a license from the Board:

(A) Category 1: commercial drilling or plugging of groundwater wells including test drilling for groundwater, and commercial drilling or plugging of fresh water observation wells;

(B) Category 2: commercial drilling or plugging of monitoring wells and site assessment wells, and drilling or plugging of geotechnical borings;

(C) Category 3: commercial installation of water well pumps;

(D) Category 4: commercial drilling or plugging of wells utilized for heat exchange purposes including but not limited to the following:

(i) heat exchange wells; and

(ii) geothermal wells.

(2) The license issued by the Board shall indicate on its face each category and specific activity or activities as described in (a)(1) of this section for which the licensee is certified to perform and conduct.

(3) Each licensed firm shall have at least one operator who may also be the licensee. Each operator shall be required to obtain a certification from the Board. An operator shall not conduct types of activities not authorized for the licensee under whom the operator works.

(4) To engage in activities for which certification is required, operators shall also have a valid license or shall be certified as an operator for a person having a valid license. An operator's certification by itself shall not constitute proper authority to engage in activities for which licensing is required.

(5) Reconditioning of wells as a trade, business or occupation for compensation shall be considered commercial drilling.

(6) No license shall be required for any person who installs vapor observation wells within the excavation of newly installed

underground tank systems, provided that the bottom of the vapor observation well does not intercept the groundwater table and is above the historic high water table level in the area, and provided further that such vapor wells shall be constructed to meet or exceed the minimum standards for the construction of monitoring wells which are located in the unsaturated zone of aquifer.

(b) **Application requirements for license.**

(1) Any person who intends to conduct any of the activities listed in 785:35-3-1(a)(1) must complete and file a verified application for license and activity certification on forms provided by the Board.

(2) The license applicant shall submit the following with the application:

(A) verification of at least two (2) years qualified experience in the activity or activities for which certification under the license is sought, provided that education related to the activity may be substituted for up to one (1) year of the required qualified experience;

(B) a list of all well rigs and equipment used or to be used in conducting the activities for which certification under license is sought;

(C) the license fee for each activity for which certification under the license is sought;

(D) the indemnity fund fee for each category of activity for which certification under the license is sought;

(E) the examination fee.

(3) Applicants who are partnerships, corporations or other entities that are not individuals shall additionally provide the following with the application:

(A) designation of one contact person who shall be an official properly authorized to act for the partnership, corporation or other entity and who shall be a certified operator;

(B) authorized signature of the contact person who shall execute and verify the application;

(C) a list of all persons employed who intend to become duly certified operators for the partnership, corporation or other entity.

(c) **Application requirements for operator certification.**

(1) Any individual who intends to conduct any of the activities listed in 785:35-3-1(a)(1) for any person who obtains a license pursuant to these rules must complete and file an application for an operator certification on forms supplied by the Board, provided however, one operator certification shall be issued with the license to the licensee.

(2) The applicant for an operator certification shall submit the following with the application:

(A) verification of at least one (1) year of qualified experience in the activity or activities for which the operator certification is sought, provided that education related to the activity may be substituted for up to six (6) months of the required qualified experience;

(B) the operator certification fee;

(C) the examination fee.

(d) **Completion of application and notification.**

(1) Any application for license or operator certification not completed within six (6) months from the date of receipt shall be cancelled and fees submitted therewith forfeited.

(2) Upon receipt of a properly completed application and all items required to be submitted, the Board shall inform said applicant of the dates, times, and places of the examination for which he is eligible.

(e) **Administration and procedures relating to examination.**

(1) Upon notification of the dates, times, and places of examinations, the applicant shall notify the Board of the date, time, and place the applicant will be present to take the examination relating to the activities listed in 785:35-3-1(a)(1) for which the license or operator certification is sought. There shall be four (4) kinds of examinations:

(A) an examination relating to groundwater wells and fresh water observation wells,

(B) an examination relating to monitoring wells, site assessment observation wells, and geotechnical boring,

(C) an examination relating to pump

installation activities, including but not limited to related electrical work performed from the output side of a fused disconnect or breaker box, and

(D) an examination relating to heat exchange wells.

(2) The applicant shall not be allowed to confer with any other person or refer to outside materials for answers to examination questions.

(3) After completion of the appropriate examination(s) within a reasonable time, the Board shall grade the examinations and pass upon qualifications of applicants for licensing and certification.

(4) An applicant, at any time within 30 days of the date he is notified of the results of an examination, may inspect his or her examination paper in the offices of the Board during the normal business hours for the purpose of challenging the propriety of the questions, the method of grading, and the accuracy of grading.

(5) Any applicant who fails an examination will be promptly notified by the Board. After a minimum time period of thirty (30) days, and if a subsequent examination is scheduled between the date of notification and the six (6) months expiration period of the application, the applicant may request to take the subsequent examination but must pay the appropriate examination fee each time the applicant requests to take the examination.

(f) **Issuance of license.**

(1) Upon acceptance of the applicant's qualifications the Board will issue the license with appropriate category and activity certifications to the applicant along with the required operator certifications.

(2) No license and no operator certificate shall be issued to any person who has not been a resident of the State of Oklahoma for at least ninety (90) days prior to the date of issuance of the license, unless the reciprocity provisions for nonresidents as set forth in (B) of this paragraph apply.

(A) The applicant for a license or operator certificate as the case may be, shall submit written verification of Oklahoma residency as required in this subsection.

(B) The Board may waive the ninety (90) day residency requirement as outlined in this subsection for any nonresident of the State of Oklahoma if the nonresident's particular state, territory, or possession of the United States extends similar privileges to the persons licensed under the provisions herein. If the applicant's state of residency has a licensing requirement, then the nonresident must be licensed and in good standing in that state. The license fees charged to a nonresident applicant shall be at least equal to the fees charged for similar nonresident license by the state, territory, or possession of the United States in which the applicant is a resident, but in no case shall the fee be less than four hundred dollars (\$400.00).

(g) **Changing the designation of license or moving an operator certification.**

(1) Any individual licensee may request modification of the license designation to that of a partnership, corporation or other legal entity. The Board shall approve the request and issue a modified license after the following conditions are met:

(A) the licensee holds an active valid license;

(B) the licensee gives written notice of the request to the Board;

(C) the licensee provides the name of the contact person who is an official properly authorized to act for the partnership, corporation or other entity;

(D) a list of all persons employed by the partnership, corporation or other entity who are or intend to become duly certified operators.

(E) payment of fee(s) required for change of license and any new operator certifications.

(2) An operator who has obtained a certification to drill under the license of a partnership, firm, or corporation can transfer that certification to another partnership, firm, or corporation on the following conditions provided that an operator cannot conduct activities during any period that he is not associated with a licensee, and provided further that an operator certification will not be

renewed unless the operator is associated with a licensee:

- (A) the transfer fee is submitted to the Board with the transfer request, and
- (B) the operator associates with the new licensee within thirty (30) days, or has provided notice to the Board of his current address within thirty (30) days after leaving the previous licensee.

(h) Adding activities to be certified under license or operator certification.

(1) A licensee or certified operator may request to add activities to be certified under the license or operator certification.

(2) The Board shall consider approval of request after the following conditions are met:

- (A) verification of at least two (2) years qualified experience in the additional activity or activities for which the license is sought, provided that education related to the activity may be substituted for up to one (1) year of the required experience; verification of at least one (1) year qualified experience in the additional activity or activities for which certification is sought, provided that education related to the activity may be substituted for up to six (6) months of the required experience;
- (B) submittal of an update of the list of rigs or other equipment to be used in the additional activity or activities;
- (C) submittal of the additional license or operator certification fee;
- (D) submittal of the additional indemnity fund fee;
- (E) submittal of the examination fee;
- (F) passing the examination.

[Source: Amended at 10 Ok Reg 3299, eff 6-25-93; Amended at 11 Ok Reg 2947, eff 6-13-94; Amended at 12 Ok Reg 2703, eff 7-1-95; Amended at 15 Ok Reg 2440-2442, eff 6-11-98; Amended at 16 Ok Reg 2687-2689, eff 7-1-99; Amended at 19 Ok Reg 2501, eff 7-1-2002; Amended at 21 Ok Reg 2634, eff 7-1-2004; Amended at 22 Ok Reg ____, eff 7-1-2005]

785:35-3-1.1. Activities authorized; electrician and plumbing license

(a) *The provisions of the Electrical License Act in Sections 1680 through 1697 of Title 59 of the Oklahoma Statutes shall not apply to . . . the*

installation, maintenance, repair or replacement of water supply pumps and related equipment and devices, provided such work is performed from the output side of a fused disconnect or breaker box. [59:1692(A)(6)]

(b) Persons holding a license or operator certification from the Board are not required to become licensed under the Electrical Licensing Act for the installation, maintenance, repair or replacement of water supply pumps, provided the work conducted by persons holding licenses or operator certifications from the Board is performed from the output side of a fused disconnect or breaker box.

(c) Persons holding a license or operator certification from the Board are not required to become licensed under the Plumbing Law of 1955 in Sections 1001 through 1023.1 of Title 59 of the Oklahoma Statutes for the installation, maintenance, repair or replacement of water supply pumps and related equipment and devices, provided the work conducted by persons holding licenses or operator certifications from the Board is performed from the water well to the pressure tank, including the shut off valve between the pressure tank and supply line on the discharge side of the pressure tank.

(d) Persons holding a license or operator certification for Category 3 Activities, Commercial Installation of Water Well Pumps, are authorized to plug permanently abandoned fresh water wells or test holes if the water in the well or test hole is uncontaminated, provided that persons shall comply with 785:35-11-1 and successfully complete a Board examination for such abandonment activities.

[Sources: Added at 23 Ok Reg ____, eff 7-17-2006

785:35-3-2. Expiration and renewal of licenses and certifications

(a) **Expiration.** All licenses and operator certifications issued by the Board shall expire on June 30 of the first or second year following issuance of the license or operators certification. New licenses or operator certifications shall be issued for a one or two year period, so that all odd license numbers and associated operators certifications shall expire in odd numbered years and all even numbered licenses and associated operator certifications shall expire in even

numbered years.

(b) **Renewal.** All licenses and certifications may be renewed for a period of two years, subject to the rules in this Chapter. On or before May 31 of the year the license or certification is to be renewed, except as specified in this subsection, each licensee and certified operator shall submit the following:

- (1) A completed application for renewal on forms furnished by the Board with the affidavit executed by the listed contact person for the licensee, and
- (2) The license or operator certification renewal fee as provided for in these rules, provided that renewal fees shall not be due for licenses and certifications issued after January 1 of the year in which the first renewal is due, and
- (3) The indemnity fund fee for those activities for which the license or operator certification is valid, and
- (4) The late fee if the renewal application is submitted after June 30.

(c) **Grace period.** Any licensee or operator who allows his or her license or certification to lapse will be given until July 31 of the year in which they are scheduled to renew their license or operator certification in which to renew his or her license or certification without an examination; provided however, a late fee shall be due after June 30 as set forth in 785:5-1-11. After the grace period, the application will be treated as a new application.

(d) **Board action.** The Board may grant the renewal application or deny the application as provided in this subchapter of these rules.

(e) **Continuing education requirement.**

- (1) Beginning July 1, 2004, completing annual continuing education shall be required before any license or operator certification will be renewed, unless otherwise specifically determined by the Board or as set forth in paragraph (8) of this subsection. Information concerning the continuing education attended must be submitted with the application for renewal form.
- (2) All licensees and all certified operators shall be required to attend at least four (4) units of approved continuing education during each year period (from July 1 through June 30) or a total of eight (8) units for each two-year period of renewal.

(3) Continuing education shall be required during the first full year that the license or operator certification is active and during each year the license or operator certification is renewed.

(4) One unit of continuing education shall equal fifty (50) minutes of approved instruction.

(5) Approved trade shows and exhibitions attended shall be counted as one unit.

(6) Continuing education instruction relating to well drilling and plugging and pump installation which are provided by or approved by another state's well drilling program are pre-approved for the Oklahoma continuing education requirement.

(7) Other continuing education instruction and trade shows and exhibitions will be considered for approval by the Board after information concerning the continuing education or trade show and exhibition is submitted to the Board for review. Pre-approval of continuing education, trade shows and exhibitions may be requested for any licensee or certified operator.

(8) If a licensee or certified operator fails to attend four (4) or eight (8) units as the case may be during the renewal period, the application for renewal may be approved after payment of \$250.00 in penalty and double the continuing education requirements (eight (8) or sixteen (16) units as the case may be).

[Source: Amended at 10 Ok Reg 3299, eff 6-25-93; Amended at 11 Ok Reg 2947, eff 6-13-94; Amended at 12 Ok Reg 2703, eff 7-1-95; Amended at 14 Ok Reg 2783, eff 7-1-97; Amended at 15 Ok Reg 2443, eff 6-11-98; Amended at 19 Ok Reg 2503, eff 7-1-2002; Amended at 20 Ok Reg ____, eff 7-11-2003]

785:35-3-3. Revocation, suspension or non-renewal of licenses and certifications

(a) **Grounds for revocation, suspension or non-renewal of licenses and certifications.** The license or certification issued under this subchapter of any person who violates any provisions of the rules and regulations of the Board may be revoked, suspended, or renewal thereof denied by the Board. Grounds for revocation, suspension or denial of renewal shall include:

(1) Failure to submit properly completed multi-purpose completion reports in the time specified by this chapter of these rules.

(2) Failure to advise a person for whom a well is being drilled or pump installed that polluted water has been encountered, and that the well is a pollution hazard and must be forthwith plugged in accordance with the rules of the Board in this chapter.

(3) Being found to be incompetent at any activities for which the license or certification was issued.

(4) Intentional misrepresentation of material fact in connection with any information or evidence furnished the Board in connection with official Board matters.

(5) Aiding or abetting an unlicensed person to evade the provisions of this chapter of these rules; knowingly combining or conspiring with an unlicensed person; allowing one's license to be used by an unlicensed person; or acting as agent, partner, associate, or otherwise of an unlicensed person with the intent to evade the provisions of this chapter of these rules.

(6) Failure in any material respect to comply with the provisions of this chapter of these rules, including the payment of fees.

(7) Failure to reimburse the Indemnity Fund as required by the Board pursuant to OAC Section 785:35-1-5.

(b) **Notice and hearing on revocation, suspension or non-renewal of license.** The Board shall, before suspending, revoking or denying renewal of any license or operator certificate, notify the licensee or operator in writing of any changes made in order to afford such licensee or operator an opportunity to be heard unless the public health, safety or welfare imperatively requires emergency action. The hearing will be conducted in accordance with Article II of the Administrative Procedures Act (75 O.S. 2001, § 308a et seq., as amended) and OAC Title 785, Chapter 4.

(c) **Board action.**

(1) If the Board determines that the public health, safety or welfare requires emergency action, it shall issue an emergency order summarily suspending the license or operator certificate pending a hearing and order such emergency remedial measures as are deemed necessary to prevent pollution to

waters of the state or other public harm.

(2) After notice and hearing, the Board may revoke, suspend or deny renewal of the license or operator certificate or order such other action as deemed appropriate. The Board may establish a probationary period and condition the continuing validity of the license on such probationary period and upon other actions, including but not limited to the proper casing or plugging of wells or such other remedial measures as deemed appropriate. In addition, the Board may impose administrative penalties as provided in 785:35-1-4(b).

[**Source:** Amended at 10 Ok Reg 3299, eff 6-25-93; Amended at 11 Ok Reg 2947, eff 6-13-94; Amended at 19 Ok Reg 2503, eff 7-1-2002]

SUBCHAPTER 5. GENERAL REQUIREMENTS TO MAINTAIN LICENSES AND OPERATOR CERTIFICATIONS

Section

785:35-5-1. General requirements for licenses

785:35-5-2. General requirements for certified operators

785:35-5-3. Requirement for multi-purpose completion report

785:35-5-1. General requirements for licenses

All licensees shall comply with the following to maintain their license:

(1) Designate in a writing filed with the Board an authorized representative of the licensee who shall be deemed and treated as responsible for the exercise, use, maintenance, modification, renewal and all other respects of, and all reports and correspondence relating to, the license. The licensee representative need not be an operator.

(2) An operator certified for the activity being conducted shall be present at the drilling, plugging or pump installation site at all times when any of the regulated activities are being conducted. The operator must have his certification in his possession anytime he is in charge of the drilling operations or pump installation activities.

(3) Each rig used in drilling or pump

installation operations shall be properly identified with letters that are a minimum of two inches (2") inches in height, with the firm name and license number in a location visible to the public.

(4) Complete each well or install each pump as the case may be to meet or exceed the minimum standards adopted by the Board set forth in this Chapter, unless a variance has been requested and approved pursuant to 785:35-7-3 before construction begins.

(5) Submit a multi-purpose completion report acceptable to the Board for each new well constructed, each well plugged and each well reconditioned on the appropriate form provided by the Board within sixty (60) days following the completion of new construction, plugging, or reconditioning of the well. The report shall include all applicable information required in the form. For test holes and geotechnical borings, a multi-purpose completion report for each test hole and boring, or one multiple test hole/boring report on a form provided by the Board listing the required information for each such test hole or boring on a contiguous tract of land, must be submitted to the Board within sixty (60) days after completion and plugging of the test holes or borings. Licensees are responsible for the accuracy of information in all reports submitted by certified operators.

(6) Properly renew said license as required herein, including continuing education attendance.

(7) Post the license issued by the Board in a conspicuous place at the business address of the licensed individual, partnership, firm or corporation.

(8) Construct and complete water wells which are to be used for purposes other than domestic use only when an application has been made to the Board for a permit authorizing the location of the well(s).

[Source: Amended at 10 Ok Reg 3299, eff 6-25-93; Amended at 11 Ok Reg 2947, eff 6-13-94; Amended at 13 Ok Reg 2885, eff 7-1-96; Amended at 15 Ok Reg 2443, eff 6-11-98; Amended at 19 Ok Reg 2504, eff 7-1-2002; Amended at 20 Ok Reg _____, eff 7-11-2003]

785:35-5-2. General requirements for

certified operators

All certified operators shall be required to do the following to maintain their certification:

(1) Complete each well or install each pump to meet or exceed the minimum standards adopted by the Board in this Chapter.

(2) Provide accurate information for any reports or other documents filed with the Board.

(3) Properly renew said certification as required herein, including continuing education attendance.

(4) Have in his possession the operator certification any time he is in charge of drilling or pump installation operations.

785:35-5-3. Requirements for multi-purpose completion report

Each licensee or certified operator as the case may be shall file a multi-purpose completion report for each groundwater well, water well test hole, fresh water observation well, monitoring well, site assessment well, geotechnical boring, or heat exchange well completed or plugged. The report shall be on forms provided by the Board and shall be filed within sixty (60) days after the date of completion or plugging. Information regarding multiple monitoring wells, geotechnical borings and heat exchange wells may be accumulated together in a single report if all of the excavations are located in the same ten-acre tract, have substantially the same lithology encountered in the subsurface, and have substantially the same depth and construction. If more than one boring or well is included on a multi-purpose completion report, a site map shall be attached to the report which indicates the distance of each well or boring from permanent reference points such as streets, roads or section lines. Provided, a report need not be filed for a geotechnical boring 20 feet deep or less in which groundwater or contamination is not present.

[Source: Amended at 19 Ok Reg 2504, eff 7-1-2002]

SUBCHAPTER 7. MINIMUM STANDARDS FOR CONSTRUCTION OF WELLS

Section

785:35-7-1. Minimum standards for construction of groundwater wells,

- fresh water observation wells, and water well test holes
- 785:35-7-1.1 Minimum standards for construction of heat exchange wells
- 785:35-7-2. Minimum standards for construction of site assessment observation wells, monitoring wells and geotechnical boring wells and geotechnical borings
- 785:35-7-3. Variances to minimum standards for construction of wells

785:35-7-1. Minimum standards for construction of groundwater wells, fresh water observation wells, and water well test holes

(a) **General requirements.**

(1) **Minimum standards.** The minimum standards set forth in this subchapter apply to all groundwater wells, fresh water observation wells and water well test holes whether constructed by a person having a valid license or by any other person.

(2) **Construction of wells.** Flowing and non-flowing groundwater wells, observation wells and water well test holes are to be constructed in a manner as to prevent waste and to prevent contamination of groundwater by pollution material either entering the ground around the casings or tubing, or entering the fresh groundwater from pollution sources below the ground, or by entering the fresh well water by leaking wells, casing pipe fittings, pumps, or well seals.

(3) **Proper maintenance, plugging and capping.** The well driller and/or the well owner are charged with the responsibility of taking whatever steps are reasonable in a particular situation to guard against waste and contamination of the groundwater resources, and to see that unused wells are properly capped or plugged.

(b) **Minimum location standards.**

(1) Every new groundwater well, fresh water observation well and water well test hole shall be located a minimum distance from possible pollution sources as prescribed in this subsection or as otherwise authorized by a variance granted by the Executive Director. Possible pollution sources include but are not limited to existing or proposed septic tanks,

sewer lines, absorption fields or beds, seepage pits, building foundations, waste pits, lagoons, oil or gas wells, and landfills. The minimum distance between the possible pollution source and the well or test hole shall be as follows, provided that other governmental agencies may require wells to be located at distances greater than the minimum distances set forth in this paragraph:

(A) 10 feet from a closed or tight sanitary sewer line,

(B) 300 feet from the outside perimeter of an existing or proposed waste lagoon for a feedlot or confined animal feeding operation, and

(C) 50 feet from all other pollution sources, provided however, if the well is 50 feet to 75 feet and located down-gradient or level from a possible source of pollution, a twenty foot (20') surface seal shall be installed, and

(D) 75 feet from all other pollution sources if the well is level with the pollution source and 100 feet from all other pollution sources if the well is located down-gradient from the pollution source.

(2) If not prohibited by the owner of the well or other governmental agency requirements, groundwater wells which will not be used for drinking water may be located closer to a possible pollution source than the minimum distances specified in paragraph (1) of this subsection if all of the following conditions are met:

(A) the possible pollution source is not a wastewater lagoon,

(B) before the well is drilled, the well driller advises the person wanting the well drilled that the well is subject to contamination,

(C) the owner of the proposed well notifies the Board that the owner will authorize the driller to drill the well closer to the possible pollution source than the minimum location standard,

(D) the outside water-tight casing is properly cement grouted or completed with ten (10) feet bentonite in the lower one-half (1/2) portion and ten (10) feet

cement grout in the upper one-half (1/2) portion at least twenty (20) feet down from the land surface or pitless adaptor connection.

(3) If a well driller or other person proposing to drill a well encounters a structure, object or other situation and is unsure whether it may be a possible source of pollution, he shall contact Board staff and obtain approval for location of the well.

(c) **Casing of groundwater and fresh water observation wells.** Except for sand point wells, requirements for casing of groundwater wells and fresh water observation wells shall be as follows:

(1) The casing shall be installed to seal off any groundwater zones containing water which does not meet the groundwater quality standards as set forth in Oklahoma's Water Quality Standards. In no case shall a well be completed in a salt water zone.

(2) New groundwater and fresh water observation wells shall have:

(A) Outside water-tight production casing cement grouted from land surface to a minimum depth of ten (10) feet below the land surface, and to such further depth as may be necessary, depending upon the character of the underground formations, to extend into an impervious stratum, where such stratum is found above the source aquifer.

(B) Casing seated at top of the first impervious stratum suitable for casing point. Where an impervious formation or tight confined bed does not occur at the well site, the casing shall be extended as far as practicable below the water table and wherever possible, at least ten (10) feet below the minimum seasonal stage of the water table.

(C) Casing joints threaded, welded, or glued with water well construction glue so as to be water-tight.

(D) Casing that extends at least eight (8) inches above the natural ground level or preferably twelve (12) above the natural ground level or eight (8) inches above the floor surface for surface pad completions.

In areas where known flooding occurs, the casing shall extend twenty-four (24) inches above the maximum level of such

flooding.

(E) Casing meeting or exceeding the following:

(i) new or clean and sanitary used carbon or stainless steel, or
 (ii) new PVC fresh water well casing which has a S.D.R. rating of twenty-six or stronger and which may be plain end with threaded connector, and with all joints made water-tight by cleaning and cementing, using manufacturer's recommended thinner and cement for use in fresh water wells, or

(iii) fiberglass or other material which meets or exceeds N.S.F. approval for casing which is specially designed for use in a water well.

(d) **Cement grouting and concreting.** Except for sand point wells, cement grouting and concreting requirements for groundwater wells and fresh water observation wells shall be as follows. These requirements must be met before the drilling rig is taken from the site.

(1) All new groundwater wells and fresh water observation wells shall be made water-tight around the outside of the production casing by cement grouting to such depths as may be necessary to exclude pollution, but in no case shall the cement grout seals be less than ten (10) continuous feet in depth, provided that five (5) feet of bentonite may be installed immediately below five (5) feet of cement grout for the total 10 feet continuous seal. If surface pipe and production casing are used, the cement grouting and/or bentonite seal shall be installed outside the surface pipe casing in all instances beginning July 1, 2005, provided the following provisions apply:

(A) a variance may be issued by the Director for an alternative completion design due to site specific conditions, and

(B) if a sleeve is used at the surface for the sole purpose of attaching a pitless adaptor, the sleeve shall be installed or embedded within the surface seal, extend a minimum of eight feet (8')

below ground level in the borehole, and the surface seal shall be a minimum of one and one-half inch (1½") thick.

(2) The cement or cement/bentonite seal shall originate at a minimum ten (10) foot depth and terminate no deeper than four feet (4') from the natural land surface after all settling of the cement or bentonite/cement has occurred, unless a written waiver is first obtained from the Board.

(3) The cement grout shall consist of a mix ratio of one (1) 94 pound sack of cement to a maximum of six (6) U.S. gallons of water. The cement and water must be mixed to the proper consistency as recommended by the cement manufacturer before the mixture is installed around the casing. A maximum of fifty percent (50%) aggregate by dry weight may be added to the portland cement to form the cement grout, provided the aggregate is a size that will not create a potential to cause bridging in the annular space.

(4) A maximum of twenty percent (20%) percent bentonite may be added to the slurry, which bentonite shall be prehydrated to the manufacturer's recommended consistency. Prehydration requires that the bentonite be properly mixed with the recommended amount of water before the mixture is installed.

(5) The well borehole shall be a minimum diameter of at least three (3) inches greater than the outside diameter of the well casing or production tubing adjacent to the borehole utilized in the surface seal.

(6) This annular space shall be filled with cement grout or cement/bentonite to the minimum ten (10) foot depth, or such further depth as may be necessary to exclude pollution.

(7) Where a pitless well adapter or unit is being installed, the grouting shall start below the junction of the pitless well adapter or unit where it attaches to the well casing and shall continue to at least ten (10) feet below this junction.

(8) If a high solids bentonite grout is used for the bentonite seal portion below the cement grout portion of the surface seal, the grout shall contain a minimum, twenty percent (20%) solids by dry weight.

(9) It is not an acceptable installation method to install dry cement around the casing and then add water.

(e) **Well development requirements for groundwater wells except sand point wells or fresh water observation wells.** Upon completion of the groundwater well or fresh water observation wells and before conducting the yield of drawdown tests, the well driller shall clean and develop the well to remove drill cuttings and drilling mud.

(f) **Disinfection of groundwater or fresh water observation wells.** Requirements for disinfection of groundwater or fresh water observation wells shall be as follows:

(1) All water used in the drilling of the well shall be potable water or uncontaminated chlorinated water having not less than 100 parts per million chlorine.

(2) A new, repaired, or modified well shall first be thoroughly cleaned and prepared for receiving pumping equipment.

(3) Thereafter, the well and pumping equipment shall be disinfected with chlorine so applied that a concentration of at least one hundred (100) parts per million of chlorine shall be obtained in all parts of the water in the well.

(4) A minimum contact period of two (2) hours shall be provided before pumping the well to flush chlorine solution from the fresh water distribution system.

(g) **Access port or water level measuring device.** Upon completion of a new groundwater or fresh water observation well and before the well is put into service, the well driller will equip the well with either an access port that will allow for the measurement of the depth to static water surface or a static water level measuring device.

(h) **Sand point well construction requirements.** Unless otherwise approved by variance, applicable minimum standards set forth in this section and the following minimum construction requirements apply to sand point wells:

(1) The sand point well shall be drilled to a total depth of no more than thirty feet (30'); and

(2) A pilot hole shall be constructed first, with cement installed to a depth of three feet (3') around surface casing, then the

remaining bore hole can be installed then production casing installed.

[Source: Amended at 10 Ok Reg 3299, eff 6-25-93; Amended at 11 Ok Reg 2947, eff 6-13-94; Amended at 13 Ok Reg 2886, eff 7-1-96; Amended at 15 Ok Reg 2444-2445, eff 6-11-98; Amended at 19 Ok Reg 2505, eff 7-1-2002; Amended at 20 Ok Reg ____, eff 7-11-2003; Amended at 21 Ok Reg 2636, eff 7-1-2004; Amended at 22 Ok Reg ____, eff 7-1-2005; Amended at 23 Ok Reg ____, eff 7-17-2006]

785:35-7-1.1. Minimum standards for construction of heat exchange wells

(a) **General requirements.**

(1) **Applicability of minimum standards.** The minimum standards set forth herein apply to all heat exchange wells as defined in 785:35-1-2, whether constructed by a person having a valid license or by any other person.

(2) **Prohibition against other uses.** Heat exchange wells cannot be used for any purpose other than heat exchange. After completion, heat exchange wells shall not be converted to any other type of well except by written approval by the Board. The licensee shall ensure that the heat exchange well is constructed according to the rules.

(3) **Maximum protection of groundwater required.** Construction of geothermal and heat exchange wells shall provide maximum protection to the groundwater from contamination and movement and migration of water from one zone or aquifer to another.

(b) **Location of heat exchange wells.**

(1) A vertical heat pump well shall be located on a site so that surface water will not pool or pond around or within ten (10) feet of the heat exchange well location.

(2) Placement of a heat exchange well must meet or exceed standards as set forth by section 785:35-7-1(b) relating to location requirements for groundwater wells except as set forth in paragraph 3 of this subsection.

(3) If not prohibited by the owner of the well or other federal or state agency requirements, heat exchange wells may be located closer to a possible source of pollution than the minimum distances specified in Section

785:35-7-1(b) if all of the following conditions are met:

(A) The possible pollution source is not a wastewater lagoon.

(B) The well annulus is completely sealed as described in paragraph 7 of subsection (c) of this section.

(c) **Construction standards for vertical closed-loop exchange wells.** Vertical closed-loop heat exchange wells shall be constructed in accordance with this subsection. Site specific conditions shall be assessed to determine the best method and materials to be used for sealing and filling the well annulus to protect the groundwater. In addition, but not as an alternative, to the requirements stated in (1) through (9) of this subsection, methods and materials for construction of heat exchange wells that meet or exceed recommendations specified in "Grouting for Vertical Geothermal Heat Pump Systems Engineering Design and Field Procedures Manual", International Ground Source Heat Pump Association, Oklahoma State University, First Ed. 2000, and in "Grouting Procedures for Ground Source Heat Pump Systems", International Ground Source Heat Pump Association, Oklahoma State University, 1991, may be used for construction of vertical closed-loop heat exchange wells.

(1) **Casing material.** If permanent casing is needed in a heat exchange well, it must meet standards set out in Section 785:35-7-1 for steel and for plastic.

(2) **Heat exchange loop material.** In a closed-loop heat exchange well, the material used to make up the heat exchange loop that is placed into the ground must be equal to or exceed PE3408, DR 11, 160 PSI high density polyethylene (HDPE) or ASTM D-3350.

(3) **Connecting closed-loop pipe.** All pipe joints and fittings installed and buried shall be socket, butt or thermally fused according to the pipe manufacturer's specifications. Glued or clamped joints shall not be used below ground unless the joint or connection serves as a service outlet and the joint or connection is not covered with earth material. Joints must not leak after assembly.

(4) **Heat transfer fluid.** The fluid used inside the closed-loop assembly must be non-toxic, food grade quality and approved for use by the U.S. Environmental Protection Agency

and a release of the fluid to the groundwater must not violate Oklahoma Water Quality Standards set forth in Chapter 45, OAC 785.

(5) **Borehole size.** The hole size for heat exchange wells must be of sufficient size to allow placement of the material to surround all pipe, but in no case shall the borehole diameter be less than four (4) inches.

(6) **Grouting of vertical heat exchange wells.** Grouting and filling the annulus of a heat exchange well must be completed after the well is drilled to avoid cave-in of the uncased hole, provided that no heat exchange boring shall be left open over twenty-four (24) hours if groundwater is encountered, or seventy-two (72) hours if groundwater is not encountered.

(7) **Vertical heat exchange well sealing and filling materials and methods.** The well annulus must be completely sealed or filled the total length of the borehole with approved materials and methods as listed below.

(A) A bentonite, cementitious, or Portland cement grout seal shall be installed from a point thirty (30) feet below land surface up to the excavation trench that connects the closed loop to the heat exchange system. Spreading or expanding clips shall not be used within the top thirty (30) feet of the borehole.

(B) Approved annulus sealing and filling materials below thirty (30) feet shall include Portland cement, high solids bentonite grout (20-30% solids by weight), bentonite pellets or chips, water well filter pack sand or gravel, or approved high efficiency or thermally enhanced grouts designed for geothermal borehole.

(C) The annulus sealing or fill material shall be installed from the bottom of the borehole to a termination point of no less than thirty (30) feet from land surface.

(D) Bentonite chip or pellet fill material installed shall be hydrated immediately after installation if installed in the unsaturated zone.

(E) Fill material placed in the annulus shall be uncontaminated, provided that cuttings shall not be used as fill material unless the cuttings are dry, uncontaminated sands or gravels

containing less than ten percent (10%) clay.

(F) When non-slurry sealing and filling materials are used, only clean water well filter pack sand or gravel or chipped or pelletized sodium bentonite varieties that are designed to fall through standing water are acceptable when sealing the annulus of a well that is below the water level in the saturated zone. The borehole shall be flushed clean of all drilling mud and debris left over from the drilling operation so that the bentonite products designed for this type of installation will gravity feed without obstruction. Material shall be introduced in a manner to prevent bridging of the materials in the borehole annulus. A measuring device such as a tagline shall be used to measure and document placement of the materials installed.

(G) Slurry mixes of bentonite grout or Portland cement shall be installed by pumping through a tremie pipe in a continuous operation using a positive displacement method. Polymer additives designed to retard swelling are acceptable for use with the bentonite grout or Portland cement. The tremie pipe will extend the full depth of the borehole before pumping begins. The borehole diameter shall be of adequate size to allow proper placement of materials using this method. Slurry volume used must equal the annulus volume of the borehole.

(H) For air drilled boreholes in which the borehole is completely dry and the normal static water level is deeper than the total depth of the heat exchange well, the bentonite slurry may be pumped from the surface without a tremie pipe.

(8) **Multiple formations, lost circulation zones, or zones of differing water quality.** When multiple formations, lost circulation zones, or zones of differing water quality are encountered within the same borehole, the listed sealing and filling materials set forth in paragraph (7) may be used, provided, that if sand or gravel material is used as the fill material, a solid plug of Portland grout, bentonite pellets, or bentonite chips must be

installed to separate the formations or zones to prevent cross contamination. The total length of the plug must be a minimum of five (5) feet and installed in a consolidated area of the borehole. If no consolidated area or formation is present to install the plug (such as loose sand or gravel), sand and/or gravel shall not be acceptable annulus fill material.

(9) **Wells drilled in lost circulation conditions.** If caves or large fractures are encountered in drilling the borehole, grouting may not be possible and the Board must pre-approve completion of the heat pump well in such conditions based on plans to bridge and seal such areas. If completion is not approved, the well must be properly plugged. Chipped bentonite or clean fill (gravel, sand and other appropriate material) may be used to seal small fractures.

(d) **Construction standards for open-loop and return heat exchange wells.**

(1) Open-loop heat exchange wells must meet the minimum construction standards set forth in Section 785:35-7-1 relating to groundwater.

(2) Water return wells for domestic heat exchange systems must meet the minimum construction requirements set forth in Section 785:35-7-1, and the groundwater used in the system must be returned to the same aquifer from which the groundwater was withdrawn by the open-loop heat exchange well, provided that authorization from the Oklahoma Department of Environmental Quality may also be required.

[Source: Added at 20 Ok Reg ____, eff 7-11-2003; Amended at 21 Ok Reg ____, eff 7-13-2004; Amended at 23 Ok Reg ____, eff 7-17-2006]

785:35-7-2. Minimum standards for construction of monitoring wells and geotechnical borings

(a) **General requirements.**

(1) **Applicability of minimum standards.** The minimum standards set forth herein apply to all monitoring wells, including site assessment observation wells and unsaturated zone monitoring wells, and geotechnical borings, whether constructed by a person having a valid license or by any

other person.

(2) **Construction.** Monitoring wells and geotechnical borings shall be constructed in such a manner as to prevent waste and contamination of groundwater by pollution material entering the ground around the casing or boring, by entering the wells or boring, or by entering the fresh groundwater from pollution sources below the ground.

(A) **Drilling equipment.** Drilling equipment shall be decontaminated if contamination is encountered in the well or borehole.

(B) **Drilling procedures.** Drilling procedures shall be carried out in such a manner that will prevent or minimize contamination.

(C) **Construction material.** All construction material shall be in a condition that will prevent or minimize contamination.

(3) **Proper maintenance and plugging.** The driller and the well owner are charged with the responsibility of taking whatever steps are reasonable in a particular situation to guard against waste and contamination of the groundwater resources and to see that unused wells and boring are properly plugged.

(4) **Other regulations.** These rules are minimum standards and other laws and regulations which are more stringent may be applicable.

(b) **Minimum standards for construction of monitoring wells.**

(1) **Diameter of borehole.**

(A) The diameter of boreholes for monitoring wells, with the exception of boreholes for unsaturated zone monitoring wells, shall be at least three inches greater than the nominal diameter of the well casing and screen for the entire length of the casing.

(B) The diameter of boreholes for unsaturated zone monitoring wells shall be at least one and one-half (1 1/2") inches greater than the nominal diameter of the well casing for the entire length of the casing.

(2) **Casing selection and casing joints.**

(A) All wells shall be cased. Casing material shall be selected according to groundwater geochemistry, anticipated lifetime of monitoring program, well depth, parameters to be monitored and other site specific considerations.

(B) When PVC casing is used, the casing shall meet or exceed the standard dimension ratio (SDR) of twenty-one (21).

(C) The minimum diameter for monitoring well casing shall be a nominal two (2) inches, with the exception of casing for unsaturated zone monitoring wells. The minimum diameter for unsaturated zone monitoring well casing shall be a nominal one-half inch. Methane gas probes at solid waste management sites shall be exempt from minimum casing diameter requirements.

(D) The casing shall be connected by flush threaded joints or have the ability to be connected by another mechanical method that does not introduce pollutants into the well. Glued joint casing shall not be used when monitoring organics.

(E) The casing joints shall be made water tight by a method that does not introduce pollutants into the well (e.g. wrapping the casing joint with Teflon tape or placing an o-ring or gasket in the joint).

(3) **Bottom cap required.** A bottom cap shall be installed on each monitoring well.

(4) **Screen selection and setting.**

(A) All wells shall be screened and screen material shall be selected according to groundwater geochemistry, anticipated lifetime of monitoring program, well depth, parameters to be monitored and other site specific considerations, provided that the minimum screen depth shall be two and one-half feet (2 ½') below the land surface, provided further that the minimum screen depth shall be two feet (2') below land surface for tank pit monitoring wells at tank locations regulated by the Oklahoma Corporation

Commission.

(B) The well screen shall be factory wire wrapped or factory slotted. Well screens shall not be field slotted.

(C) Slot size shall be selected to prevent or minimize infiltration of the filter pack through the well screen.

(D) Screens shall be of sufficient length to detect, monitor or otherwise describe the contaminant plume according to site specific conditions (e.g. seasonal water level fluctuations). Screen length shall be determined so that commingling of fluids from separate groundwater zones does not occur.

(E) Screen joints shall be placed in the well in such a manner as not to interfere with the accurate investigation of the groundwater quality.

(5) **Filter pack selection and placement.**

(A) All wells shall have a filter pack and aggregates used for filter pack shall consist of uncontaminated quartz sand, silica or other material that will not affect the groundwater quality.

(B) Filter pack shall be selected to prevent or minimize infiltration of the geologic formation (e.g. fines migration or sand buildup).

(C) Filter pack shall extend two (2) feet above the top of the screen unless such extension would allow vertical communication of pollution through the filter pack.

(D) Filter pack shall be placed in the annulus of the well in such a manner that bridging of the filter pack material will not occur.

(E) When water or vapor levels being monitored are encountered within five (5) feet of the land surface, the filter pack shall extend a minimum of 0.5 feet above the top of the screen.

(6) **Sealing requirements.** Requirements for proper filter pack sealing, annular sealing and surface sealing for monitoring wells shall be as follows:

(A) **Sealing material.** All sealing materials shall be compatible with ambient geological, hydrogeological and climatic conditions, as well as any man-

induced conditions anticipated to occur during the life of the monitoring well. Any cement used as a sealant shall be equivalent to or have the same properties as ASTM C-150 cement types I-V (commonly known as Portland cement).

(B) **Filter pack seal.** A minimum of two (2) feet of uniformly sized particles of sodium bentonite pellets or granules of no less than 0.25 inches and no more than 0.75 inches in size shall be placed immediately over the filter pack in each site assessment observation well or monitoring well.

(C) **Annular seal.** The annular space above the filter pack seal shall be filled with a cement grout, bentonite grout, bentonite chips or a cement/bentonite grout mixture to within two (2) feet of the surface. The cement grout shall have a mix ratio of one 94 pound sack of cement to a maximum of six U.S. gallons of water. The cement and water must be mixed to the proper consistency as recommended by the cement manufacturer before the mixture is installed around the casing. A maximum of twenty percent (20%) bentonite by dry weight may be added to the cement grout to form the cement/bentonite grout mixture. The bentonite shall be prehydrated to the manufacturer's recommended consistency. The bentonite grout shall be a high solids bentonite grout with at least twenty percent (20%) bentonite by dry weight. The bentonite shall be mixed according to the manufacturer's recommended consistency.

(D) **Surface seal.** A concrete or cement grout surface seal shall be placed around the casing immediately above the annular seal from a depth of two (2) feet to land surface.

(E) **Tremie requirements for grout.** When the placement of grout will exceed twenty (20) feet, the grout shall be placed in the annulus of the well through a tremie pipe and filled or pumped from the bottom upward.

(F) **Multiple cased or screened wells.** No adjacent or collinear casings in the same borehole shall be allowed. No multiple screened intervals in the same casing shall be allowed. Wells shall be drilled with sufficient distances between them so as to prevent the commingling of aquifer zones.

(G) **Special annular, filter pack, and surface seal conditions.** When water or vapor levels being monitored are encountered within five (5) feet of the land surface, the required depths set forth in C and D above for the filter pack and annular seals shall be reduced to fill the annular space from the top of the filter pack materials to the bottom of the cement surface seal, provided that the minimum screen depth shall be two and one-half feet (2 ½') below the land surface, provided further that the minimum screen depth shall be two feet (2') below land surface for tank pit monitoring wells at tank locations regulated by the Oklahoma Corporation Commission. The surface seal shall extend a minimum of one (1) foot below land surface.

(7) **Surface pad requirements.**

(A) A concrete or cement surface pad shall be installed around the casing at the surface with minimum dimensions of 3 feet in diameter by 3.5 inches thick.

(B) The surface pad shall be sloped so to insure that all surface water flows away from the well.

(C) The surface pad is not required if the well is completed in competent concrete or asphalt paving, or if the well is an unsaturated zone monitoring well or a site assessment well that is located in a proposed solid waste disposal site and neither is used for a period exceeding one (1) year.

(8) **Top cap requirements.**

(A) A threaded or flange cap or compression seal shall be installed upon completion of the well to prevent unauthorized use of the well (e.g. tampering with the well or the entrance of foreign material into the well).

(B) The cap or seal shall have the capability of being locked if the well is flush mounted and the well protector is not capable of being locked.

(9) **Monitoring well and site assessment observation well protection.** Protection shall be provided for the casing of monitoring wells or site assessment observation wells by either of the following methods:

(A) An aluminum or steel surface casing shall be set a minimum of 12 inches through the cement or concrete surface pad and shall extend a minimum of 24 inches above the pad or ground. The top of the protective casing shall be fitted with a locking cap and shall be marked to clearly identify the well as a monitoring well or site assessment observation well; or

(B) If flush mounting is required, then the well shall be completed with a well protector that is capable of supporting vehicular traffic, provided that flush mounting of the casing of monitoring wells installed at concentrated animal feeding operations after July 1, 2006, shall be prohibited. The well protector shall be raised a minimum of one-half (1/2) inch above the surface pad or paving and shall be clearly marked to identify the well as a monitoring well or site assessment observation well. The surface seal shall be sloped so that surface water flows away from the well protector and the bond between the well protector and the removable cover shall be made watertight.

[Source: Revoked and Reenacted at 9 Ok Reg 1679, eff 5-11-92; Amended at 10 Ok Reg 3299, eff 6-25-93; Amended at 11 Ok Reg 2947, eff 6-13-94; Amended at 13 Ok Reg 2887, eff 7-1-96; Amended at 14 Ok Reg 2784; Amended at 15 Ok Reg 2446-2447, eff 6-18-98; Amended at 19 Ok Reg 2506, eff 7-1-2002; Amended at 22 Ok Reg _____, eff 7-1-2005; Amended at 23 Ok Reg _____, eff 7-17-2006]

785:35-7-3. Variances to minimum standards for construction of wells

(a) Variances from any of the minimum standards for construction of wells set forth in this subchapter

may be granted by the Board when it is demonstrated that the construction proposed will protect the quantity and quality of the groundwater from contamination and waste. Requests for variances must be completed on forms provided by the Board and submitted prior to beginning any work related to the variance, unless otherwise approved by the Executive Director of the Board as provided in this section.

(b) Requests for variances shall be accompanied by any plans, specifications or other information detailing the type of variance requested and reasons for the variance request.

(c) Requests for variances must be signed by the licensed well driller, contain a notarized signature from the landowner of the land where the work is being done, and contain a certification signed by a licensed professional engineer that activities allowed by such variance will not cause pollution.

(d) Staff shall review the plans, specifications and data for purposes of determining the potential impacts on the groundwater and, if deemed advisable, may consult with all person requesting the variance, landowner and licensed professional engineer or hydrogeologist. Staff shall then make a recommendation to the Executive Director about the request for variance.

(e) The Executive Director may approve the requested variance, deny the requested variance, or approve the requested variance subject to certain conditions being met.

[Source: Added at 11 Ok Reg 2947, eff 6-13-94; Amended at 12 Ok Reg 2703, eff 7-1-95; Amended at 19 Ok Reg 2508, eff 7-1-2002]

SUBCHAPTER 9. MINIMUM STANDARDS FOR PUMP INSTALLATION

Section

785:35-9-1. Minimum standards for pump installation

785:35-9-2. Variances to minimum standards for pump installations

[Source: Codified 6-25-93]

785:35-9-1. Minimum standards for pump installation

(a) **General requirements.**

(1) **Minimum standards.** The minimum standards set forth in this subchapter apply to the installation of all water well pumps and pumping equipment, whether installed by a

person having a valid license or by any other person.

(2) **Pump installation practices.** All pump installations shall be completed in such a manner as to prevent waste and contamination of groundwater by pollution material entering the well from pumping equipment, casing connectors, fittings, piping, sanitary seals or caps.

(3) **Construction materials.** All materials used in the construction of the pumping system shall be of a type and strength to prevent waste or pollution of the groundwater of the state.

(4) **Temporary abandonment practices.** When a well is to be temporarily removed from service, the top of the well casing shall be properly sealed with a water-tight cap that cannot be easily removed.

(b) **Well casing connections.** Minimum standards for well casing connections are as follows:

(1) **Above-grade connection.** An above-grade connection into the top or side of a well casing shall be at least eight inches (8"), but preferably twelve inches (12"), above the land surface and shall be constructed so as to exclude dirt or other foreign matter by at least one of the following methods, as may be applicable:

- (A) Threaded connection;
- (B) Welded connection;
- (C) Rubber expansion sealer;
- (D) Bolted flanges with rubber gaskets;
- (E) Overlapping well cap; or
- (F) If a water well pump is mounted or sealed on a concrete pedestal, the casing shall extend at least one inch (1") into the base of the pedestal and at least eight inches (8") above the land surface.

(2) **Below-grade connection.** A connection to a well casing made below ground, or less than eight inches (8") above the land surface, shall be protected by a pitless adapter or pitless unit. Such pitless adapters shall be installed below the frost line. A below-ground connection shall not be submerged in water at the time of installation. Holes cut in the casing through which the pitless adapters are installed must be sized and constructed so as to guarantee a

watertight seal with the pitless adapter in place.

(3) **Above-grade capping.** For water wells with pitless adapters, the portion of the well casing above the land surface shall be capped with a water-tight, vented pitless adapter cap that cannot be easily removed.

(c) **Pump installation.** The minimum standards for installation of pumps and pumping systems are as follows:

(1) **Pumps and pumping equipment.**

(A) **Priming requirements.** A pump shall be designed, installed, and maintained so that priming is not required for ordinary use. Pumps installed on irrigation systems may be primed, but the priming water shall contain a chlorine residual and be clear and free of contamination. An irrigation well equipped with a centrifugal pump may be primed without chlorination when the pump is filled with water taken directly from the well.

(B) **Cross connections prohibited.** Cross connections between water wells and other systems or equipment containing substances such as wastewater, pesticides or fertilizers are prohibited unless equipped with a protective device such as a break tank or backflow preventer, which the owner agrees to install, test and maintain to assure proper operation.

(2) **Pump discharge lines.** A buried discharge line between the well casing and the pressure tank in any installation, including a deep well turbine or a submersible pump, shall not be under negative pressure at any time.

(3) **Vents.** All wells shall be vented with watertight joints terminating at least two feet (2') above the 100 year flood elevation or eight inches (8"), but preferably twelve inches (12"), above the land surface. The casing vent shall be screened. Vents may be offset. All submersible pumps shall be installed with a vented cap on the top of the well casing or pitless unit to prevent drawing surface water, mud, sand, or other substances into the well. Where the well casing on small diameter wells is used as a suction pipe, the casing

need not be equipped with a vented cap, provided the casing is properly sealed or capped. If toxic or flammable gases are present, they shall be vented from the well. The vent shall extend to the outside atmosphere at least six (6) feet above land surface or to a point where the gases will not present a hazard. Openings in pump bases shall be sealed watertight.

(4) **Disinfection.** The well and pumping equipment shall be disinfected with a chlorine concentration of at least one hundred (100) parts per million of chlorine throughout the well. The chlorine solution shall be introduced into the well in a manner to flush the well casing surfaces above the static water level. A minimum contact period of two (2) hours shall be provided before purging and flushing the chlorine solution from the distribution system. Disinfection in a well repair operation may be accomplished at the beginning of the operation with chlorine applied to obtain a concentration of two hundred (200) parts per million for the period of the well repair operation. The water shall be purged prior to taking of water samples or use being made of the water. The licensee or operator shall be responsible for disinfecting the well, pump or pumping equipment. The well owner may pump and flush the well following disinfection, provided the owner has been instructed regarding the proper procedures by the licensee or operator.

[Source: Added at 10 Ok Reg 3299, eff 6-25-93; Amended at 12 Ok Reg 2703, eff 7-1-95; Amended at 19 Ok Reg 2508, eff 7-1-2002; Amended at 21 Ok Reg 2638, eff 7-1-2004]

785:35-9-2. Variances to minimum standards for pump installations

(a) Variances from any of the minimum standards for pump installations set forth in this subchapter may be granted by the Board when it is demonstrated that the installation method proposed will protect the quantity and quality of the groundwater from contamination and waste. Requests for variances must be completed on forms provided by the Board and submitted prior to beginning any work related to the variance, unless otherwise approved by the Executive Director as provided in this section.

(b) Requests for variances shall be accompanied by any plans, specifications or other information detailing the type of variance requested and reasons for the variance request.

(c) Requests for variances must be signed by the licensed well driller, contain a notarized signature from the landowner of the land where the work is being done, and contain a certification that activities subject of the variance request will not cause pollution.

(d) Staff shall review the plans, specifications and data for purposes of determining the potential impacts on the groundwater and, if deemed advisable, may consult with all person requesting the variance, landowner and licensed professional engineer or hydrogeologist. Staff shall then make a recommendation to the Executive Director about the request for variance.

(e) The Executive Director may approve the requested variance, deny the requested variance, or approve the requested variance subject to certain conditions being met.

[Source: Added at 12 Ok Reg 2703, eff 7-1-95; Amended at 19 Ok Reg 2509, eff 7-1-2002]

SUBCHAPTER 11. PLUGGING AND CAPPING REQUIREMENTS FOR WELLS AND TEST HOLES

Section

785:35-11-1. Plugging and capping requirements for groundwater wells, fresh water observation wells, heat exchange wells and water well test holes

785:35-11-2. Plugging requirements for site assessment observation wells, monitoring wells and geotechnical borings

785:35-11-3. Variances to plugging requirements

785:35-11-1. Plugging and capping requirements for groundwater wells, fresh water observation wells, heat exchange wells and water well test holes

(a) **Temporary capping.** When a groundwater well or fresh water observation well is temporarily removed from service, the top of the well casing will be properly sealed with a pitless adapter cap, sanitary well seal, or well casing cap that cannot easily be removed. A new well shall be properly capped before the well driller leaves the drilling

site.

(b) **Time for plugging or completing water well test holes.** Water well test holes shall be properly plugged as provided in this section by the well driller within three (3) days after the completion of testing or such test holes must be completed as water wells, including the installation of surface casing and cement seals, within three (3) days after the completion of testing, unless an extension of time is granted by the Board. The three (3) day period for plugging or completion may be extended by the Board upon request from the well driller. Such request must be submitted prior to the end of the three (3) day period. The multi-purpose completion report shall be submitted to the Board within sixty (60) days after plugging of each water well test hole.

(c) **Permanent abandonment.** The following plugging requirements apply if a groundwater well, fresh water observation well, heat exchange well, or water well test hole is permanently abandoned, was drilled by a person not holding a valid license or operator certification from the Board, or if the Board determines that the well or test hole was not drilled or completed in compliance with the applicable minimum standards set forth in this Chapter or may otherwise allow pollution to groundwater.

(1) The well driller shall be responsible for plugging the well or test hole if the well drilling equipment is on the drilling site. If a well is abandoned after the well drilling equipment has been removed from the drilling site, the owner of the land where the well or test hole is located shall be responsible for plugging.

(2) If the well or test hole is uncontaminated and unless paragraph 3 or paragraph 5 below applies, fill such well or water well test hole with uncontaminated, compacted drill cuttings and/or uncontaminated surface clay, cement, bentonite pellets or granules, or high solids (a minimum of twenty percent (20%) solids by dry weight) bentonite grout to within fourteen (14) feet of the land surface, and a minimum of ten (10) feet of the annular space and interior of the well casing shall be filled with cement grout to at least four (4) feet below the land surface.

(3) To plug uncontaminated groundwater wells, fresh water observation wells, or heat exchange wells in the alluvium and terrace

deposits of the Arkansas, Cimarron, Salt Fork of the Arkansas, North Canadian, Canadian, Washita, North Fork of the Red, Salt Fork of the Red River, Red River, and other streams or rivers authorized by the Board, fill the well with clean, uncontaminated silica sand to within sixteen (16) feet of the land surface, then two (2) feet of bentonite pellets or granules shall be placed on the uncontaminated silica sand, and finally, a minimum of ten (10) feet of cement grout shall be installed in the annular space and interior of the well casing to at least four (4) feet below the land surface.

(4) Hand dug water wells shall be filled with uncontaminated surface clay or grout to within six (6) feet of land surface. The lining of the well shall be removed from the top five (5) feet and a minimum of two (2) feet of cement grout shall be installed. The top four (4) feet shall be filled with compacted uncontaminated native soil, unless otherwise directed by the Board.

(5) If the well or water well test hole is contaminated, or if the well or test hole is located at an underground tank site or within 300 feet of the outside perimeter of an existing wastewater lagoon or is located on a tract of land where a wastewater lagoon is proposed, the casing shall be removed or perforated from the bottom of the casing to twenty (20) feet below land surface. The casing shall be removed from twenty (20) feet below land surface to the surface, then the well or test hole shall be plugged with cement grout from the bottom to within four (4) feet below the land surface. If the total depth of the well is in excess of twenty feet (20') below land surface, the cement grout shall be placed by pumping from the bottom of the hole to the land surface.

[Source: Amended at 10 Ok Reg 3299, eff 6-25-93; Amended at 11 Ok Reg 2947, Eff 6-13-94; Amended at 12 Ok Reg 2703, eff 7-1-95; Amended at 15 Ok Reg 2448, eff 6-11-98; Amended at 16 Ok Reg 2689-2690, eff 7-1-99; Amended at 22 Ok Reg ____, eff 7-1-2005]

785:35-11-2. Plugging requirements for site assessment observation wells, monitoring wells and geotechnical borings

(a) **Monitoring wells and site assessment observation wells.** Monitoring wells and site assessment observation wells shall be plugged to prevent pollution of groundwater within three (3) days after completion of use or immediately if drilled by an unlicensed or uncertified person or if the Board determines that the well does not meet the minimum construction standards set forth in this Chapter. The following are minimum requirements for plugging monitoring wells and site assessment observation wells, and the owner of such wells or other federal or state agency may specify more stringent requirements:

(1) If no contaminated soil or contaminated groundwater is present in the well, cement grout shall be placed in the well through a tremie pipe and filled or pumped from the bottom of the well to an elevation four (4) feet below the land surface. In the alternative, bentonite pellets, granules or high solids (a minimum of twenty percent (20%) solids by dry weight) bentonite grout shall be placed from the bottom of the well to an elevation fourteen (14) feet below land surface and a minimum of ten (10) feet shall be filled with cement grout to an elevation four (4) feet below land surface, unless contaminated soil or contaminated groundwater is present in the well. The remaining four (4) feet to land surface shall be backfilled with compacted uncontaminated soil. If the depth of the well is fourteen (14) feet or less, cement grout shall be placed from the bottom of well to land surface.

(2) If contaminated soil or contaminated groundwater is present or was previously present in the well and the top of the screen is less than 20 feet below land surface, overdrilling of the well is required. The casing shall be removed or drilled out and the same size auger used to drill the borehole or larger shall be used to drill out the casing and associated seals, annular space and filter pack. Cement grout shall be placed from the bottom of the well to an elevation four (4) feet below land surface. If the top of the well screen is 20 feet or more below land surface and the well meets current minimum construction standards, then the casing need not be removed and cement grout shall be placed in the well through a tremie pipe and

filled or pumped from the bottom upward to within four (4) feet of land surface or to land surface. The remaining four (4) feet to land surface shall be backfilled with compacted uncontaminated soil.

(b) **Geotechnical borings except direct push geotechnical borings.** Geotechnical borings shall be plugged to prevent pollution of groundwater within thirty (30) days after completion of drilling or immediately if drilled by an unlicensed or uncertified person or if the Board determines that the well does not meet the minimum construction standards set forth in this Chapter. The following are minimum requirements for plugging geotechnical borings, and the owner of the boring or other federal or state agency may specify more stringent requirements:

(1) If no contaminated soil and groundwater is encountered in the boring, uncontaminated drill cuttings, uncontaminated surface clay, cement, and/or high solids (a minimum of twenty percent (20%) solids by dry weight) bentonite grout, pellets, or granules shall be placed from the bottom of the boring to an elevation fourteen (14) feet below land surface and a minimum of ten (10) feet shall be filled with cement grout to an elevation four (4) feet below land surface. The remaining four (4) feet to land surface shall be backfilled with compacted uncontaminated soil.

(2) If contaminated soil or contaminated groundwater is encountered in the boring, or if the boring is located at an underground storage tank site or within 300 feet of the outside perimeter of an existing wastewater lagoon or is located on a tract of land where a wastewater lagoon is proposed, cement grout shall be placed from the bottom of the borehole to an elevation four (4) feet below land surface. Cement grout shall be placed in the borehole through a tremie pipe and filled or pumped from the bottom upward. The remaining four (4) feet to land surface shall be backfilled with compacted uncontaminated soil.

(3) If the boring is twenty (20) feet or less in total depth and groundwater has not been encountered, the boring shall, at a minimum, be filled with compacted uncontaminated cuttings from the bottom of the boring to land

surface.

(c) **Direct push geotechnical borings.** Direct push geotechnical borings shall be plugged to prevent pollution of groundwater within thirty (30) days after completion of drilling or immediately if drilled by an unlicensed or uncertified person or if the Board determines that the well does not meet the minimum construction standards set forth in this Chapter as follows:

(1) Bentonite chips shall be placed and effectively compressed within the annulus space from the bottom of the borehole to within ten (10) feet of the land surface.

(2) Cement grout shall be installed through a tremie pipe in the remaining annulus space from ten (10) feet to land surface, provided that no cement grout shall be required if the boring is less than ten feet (10') in total depth and no groundwater and no contaminated soil was encountered.

(d) **Cement grout requirements.** If cement grout is used, the grout shall have a mix ratio of one 94 pound sack of cement to a maximum of six U.S. gallons of water.

(e) **Abandonment after equipment removed.** If a site assessment observation well, monitoring well or geotechnical boring is abandoned after the drilling equipment has been removed from the site, responsibility for proper plugging within the applicable time period specified in this section shall lie with the owner of the land where the well or boring is located

[Source: Revoked and Reenacted at 9 Ok Reg 1679, eff 5-11-92; Amended at 10 Ok Reg 3299, eff 6-25-93; Amended at 11 Ok Reg 2947, eff 6-13-94; Amended at 12 Ok Reg 2703, eff 7-1-95; Amended at 15 Ok Reg 2449, eff 6-11-98; Amended at 16 Ok Reg 2690-2691 eff 7-1-99; Amended at 19 OK Reg 2510, eff 7-1-2002; Amended at 20 Ok Reg _____, eff 7-11-2003; Amended at 21 Ok Reg 2639, eff 7-1-2004;

Amended at 22 Ok Reg _____, eff 7-1-2005; Amended at 23 Ok Reg _____, eff 7-17-2006]

785:35-11-3. Variances to plugging requirements

(a) Variances from any of the minimum standards for plugging set forth in this subchapter may be granted by the Board when it is demonstrated that the plugging method or actions proposed will protect the quantity and quality of the groundwater from contamination and waste. Requests for variances must be completed on forms provided by the Board and submitted prior to beginning any work related to activities subject of the variance request, unless otherwise approved by the Executive Director as provided in this section.

(b) Requests for variances shall be accompanied by any plans, specifications or other information detailing the type of variance requested and reasons for the variance request.

(c) Requests for variances must be signed by the licensed well driller, contain a notarized signature from the landowner of the land where the work is being done, and contain a certification that activities subject of the variance request will not cause pollution.

(d) Staff shall review the plans, specifications and data for purposes of determining the potential impacts on the groundwater and, if deemed advisable, may consult with all person requesting the variance, landowner and licensed professional engineer or hydrogeologist. Staff shall then make a recommendation to the Executive Director about the request for variance.

(e) The Executive Director may approve the requested variance, deny the requested variance, or approve the requested variance subject to certain conditions being met.

[Source: Added at 12 Ok Reg 2703, eff 7-1-95; Amended at 19 Ok Reg 2510, eff 7-1-2002]